

MATERIAL SAFETY DATA SHEET (MSDS)

SECTION 1--- PRODUCT AND MANUFACTURER

Product Name: Valve Regulated Lead Acid (VRLA) Batteries Manufacturer:

SHENZHEN CENTER POWER TECH. CO., LTD.

Center Power Industrial Park, Tongfu Industrial District, Dapeng Town,
PC518120, Shenzhen, P.R. China
Tel: (+86-755) 8431 8088
Fax: (+86-755) 8431 8700
Email: sales@vision-batt.com
Website: <http://www.vision-batt.com>

NORTH AMERICA SALES OFFICE

Suite#880-999 W. Broadway, Vancouver, B. C, Canada V5Z1K5
Tel: (604)-7302877
Fax: (604)-7302898
E-mail: vision_sales@intergate.ca
Website: www.vision-batt.com

ITALY OFFICE

Piazza Don E. Mapelli 75 20099 Sesto San Giovanni-Milano Italy
Tel: 39-02-262 7021
Fax: 39-02-262 26255
Email: konelco@konelco.it

INDIA OFFICE

C-107, Synthofine Estate, Behind Virwani Industrial Estate,
off Aarey Road, Goregaon (East), Mumbai-400 063 India
Tel: 91 22 873 9134 / 872 3569 / 690 3275
Fax: 91 22 876 2236
Email: primep@vsnl.net

SECTION 2--- HAZARDOUS COMPONENTS

Components	%Wt.	TLV	LD50 Oral	LC50 Inhalation	LC50 Contact
Lead (Pb, PbO ₂ , PbSO ₄)	About 70%	0.050mg/m ³	5(500) mg/Kg	N/A	N/A
Sulfuric Acid	About 20%	1 mg/m ³	(2.14) mg/Kg	N/A	N/A
Fiberglass Separator	About 5%	N/A	N/A	N/A	N/A
Container (ABS or PP)	About 5%	N/A	N/A	N/A	N/A

SECTION 3--- PHYSICAL DATA

Components	Density	Melting Point	Solubility (in H ₂ O)	Odor	Appearance
Lead	11.34	327.4°C	None	None	Silver-Gray Metal
Lead Sulfate	6.2	1170°C	40 mg/l (15°C)	None	White Powder
Lead Dioxide	9.4	290°C	None	None	Brown Powder
Sulfuric Acid	About 1.3(25°C)	About 114°C (Boiling)	100%	Acidic	Clear Colorless Liquid
Fiberglass Separator	N/A	N/A	Slight	Toxic	White Fibrous Glass Membrane
Container (ABS or PP)	N/A	N/A	NONE	No Odor	Solid Plastics



SECTION 4---PROTECTION

Exposure	Protection	Comments
Skin	Rubber gloves, Apron, Safety shoes	Protective equipment must be worn if battery is cracked or otherwise damaged.
Respiratory	Respirator (for lead)	A respirator should be worn during reclaim operations if the TLV exceeded.
Eyes	Safety goggles, Face Shield	In the UK use of this material must be assessed under the COSHH regulations.

SECTION 5--- FIRST AID MEASURES

Emergency and First Aid Procedures	Contact with internal components if battery is opened/broken.
1. Inhalation	Remove to fresh air and provide medical oxygen/CPR if needed. Obtain medical attention.
2. Eyes	Immediately flush with water for at least 15 minutes, hold eyelids open. Obtain medical attention.
3. Skin	Flush contacted area with large amounts of water for at least 15 minutes. Remove contaminated clothing and obtain medical attention if necessary.
4. Ingestion	Do not induce vomiting. If conscious drink large amounts of water/milk. Obtain medical attention. Never give anything by mouth to an unconscious person.

SECTION 6--- FLAMMABILITY DATA

Components	Flash Point	Explosive Limits	Comments
Lead	None	None	
Sulfuric Acid	None	None	
Hydrogen	259 °C	4%-74.2%	Emit hydrogen only if over charged (Voltage>2.4 VPC). To avoid the chance of a fire or explosion, keep sparks and other sources of ignition away from the battery. Extinguishing Media: Dry chemical, Foam, CO2
Fiberglass Separator	N/A	N/A	Toxic vapors may be released. In case of fire: wear self-contained breathing apparatus.
ABS	None	N/A	Danger: Vapors may cause Flash Fire. Harmful or Fatal if Swallowed. Vapor Harmful.
PP	None	N/A	Temperatures over 300 °C (572°F) may release combustible gases. In case of fire: wear positive pressure self-contained breathing apparatus.

SECTION 7--- REACTIVITY DATA

Components	Lead/lead compounds
Stability	Stable
Incompatibility	Potassium, carbides, sulfides, peroxides, phosphorus, sulfurs.
Decomposition Products	Oxides of lead and sulfur.
Condition To Avoid	High temperature, Sparks and other sources of ignition.

Components	Sulfuric Acid
Stability	Stable at all temperatures
Polymerization	Will not polymerize
Incompatibility	Reactive metals, strong bases, most organic compounds
Decomposition Products	Sulfuric dioxide, trioxide, hydrogen sulfide, hydrogen
CONDITIONS TO AVOID	Prohibit smoking, sparks, etc. from battery charging area. Avoid mixing acid with other chemicals.



SECTION 8---CONTROL MEASURES

1. Store lead/acid batteries with adequate ventilation. Room ventilation is required for batteries utilized for standby power generation. Never recharge batteries in an unventilated, enclosed space.

2. Do not remove vent caps. Follow shipping and handling instructions that are applicable to the battery type. To avoid damage to terminals and seals, do not double-stack industrial batteries.

STEPS TO TAKE IN CASE OF LEAKS OR SPILLS

If sulfuric acid is spilled from a battery, neutralize the acid with sodium bicarbonate (baking soda), sodium carbon (soda ash), or calcium oxide (lime).

Flush the area with water and discard to the sewage systems. Do not allow unneutralized acid into the sewage system.

WASTE DISPOSAL METHOD:

Neutralized acid may be flushed down the sewer. Spent batteries must be treated as hazardous waste and disposed of according to local state, and federal regulations. A copy of this material safety data must be supplied to any scrap dealer or secondary smelter with battery.

ELECTRICAL SAFETY

Due to the battery's low internal resistance and high power density. High levels of short circuit can be developed across the battery terminals. Do not rest tools or cables on the battery. Use insulated tools only.

Follow all installation instruction and diagrams when installing or maintaining battery systems.

SECTION9---HEALTH HAZARD DATA

LEAD: The toxic effects of lead are accumulative and slow to appear. It affects the kidneys, reproductive, and central nervous system.

The symptoms of lead overexposure are anemia, vomiting, headache, stomach pain (lead colic), dizziness, loss of appetite, and muscle and joint pain. Exposure to lead from a battery most often occurs during lead reclaim operations through the breathing or ingestion of lead dusts and fumes.

THIS DATA MUST BE PASSED TO ANY SCRAP OR SMELTER WHEN A BATTERY IS RESOLD.

SULFURIC ACID: Sulfuric acid is a strong corrosive. Contact with acid can cause severe burns on the skin and in the eyes. Ingestion of sulfuric acid will cause GI tract burns. Acid can be release if the battery case is damaged or if the vents are tampered with.

FIBERGLASS SEPARATOR: Fibrous glass is an irritant of the upper respiratory tract, skin and eyes. For exposure up to 10F/CC use MSA Comfort with type H filter. Above 10F/CC up to 50F/CC use Ultra-Twin with type H filter. NTP or OSHA does not consider this product carcinogenic.

SECTION10--- SULFURIC ACID PRECAUTIONS

Stability: Stable Substances to be avoided include water, most common metals, organic materials, strong reducing agents, combustible materials, and bases, oxidizing agents. Reacts violently with water - when diluting concentrated acid, carefully and slowly add acid to water, not the reverse. Reaction with many metals is rapid or violent, and generates hydrogen (flammable, explosion hazard).

INHALATION: Acid mist form formation process may cause respiratory irritation, remove from exposure and apply oxygen if breathing is difficult.

SKIN CONTACT: Acid may cause irritation, burns or ulceration. Flush with plenty of soap and water, remove contaminated clothing, and see physician if contact area is large or if blisters form.

EYE CONTACT: Acid may cause severe irritation, burns, cornea damage and blindness. Call physician immediately and flush with water until physician arrives.

INGESTION: Acid may cause irritation of mouth, throat, esophagus and stomach. Call physician. If patient is conscious, flush mouth with water, have the patient drink milk or sodium bicarbonate solution.

DO NOT GIVE ANYTHING TO AN UNCONSCIOUS PERSON.

SECTION 11---TRANSPORTATION REGULATIONS

We hereby certify that all VISION Rechargeable Sealed Lead Acid batteries conform to the UN2800 classification as "Batteries, wet, Non-Spillable, and electric storage" as a result of passing the Vibration and Pressure Differential Test described in DOT [49 CFR 173.159(d) and IATA/ICAO [Special Provision A48 and A67].

VISION Batteries having met the related conditions are EXEMPT from hazardous goods regulations for the purpose of transportation by DOT, and IATA/ICAO, and therefore are unrestricted for transportation by any means. For all modes of transportation, each battery outer package is labeled "NON-SPILLABLE".

U.S.DOT PROPER SHIPPING NAME: Batteries, wet, non-spillable

U.S.DOT HAZARD CLASS:8

U.S.DOT ID NUMBER:UN2800

U.S.DOT PACKING GROUP: III

U.S.DOT LABEL:CORROSIVE

OR Excepted from the requirements because batteries have passed the Vibration and Pressure Differential performance tests, and ruptured case test for Nonspillable designation

IMO PROPER SHIPPING NAME: Batteries, wet, non-spillable

IMO HAZARD CLASS:8

IMO ID NUMBER:UN2800

IMO LABEL:CORROSIVE

IMO VESSEL STOWAGE: A

IATA PROPER SHIPPING NAME: Batteries, wet, non-spillable

IATA HAZARD CLASS:8

when

IATA ID NUMBER:UN2800

U.S.DOT LABEL:CORROSIVE

ERG Code-8L

OR

Excepted from the requirements because batteries have passed the Vibration and Pressure Differential performance tests, and ruptured case test for Nonspillable designation. And

Packaged for transport, the terminals are protected from short circuit.

PROPER SHIPPING NAME	Batteries, wet, non-spillable, Electric Storage
U.S.DOT(U.S. Department of Transportation	Unregulated, meets the requirement of 49 CFR 173.159(d)
IATA(International Air Transportation	Unregulated, meets the requirements of
Association)/	
ICAO(International Civil Aviation Administration)	Special Provisions A67
IMO(International Maritime Dangerous Goods)	Unregulated



SECTION12---TOXICOLOGICAL INFORMATION

GENERAL: The primary routes of exposure to lead are ingestion of dust and fumes

ACUTE:

INHALATION/INGESTION: Exposure to lead and its compounds may cause headache, nausea, vomiting, abdominal spasms, fatigue, sleep disturbances, weight loss, anemia, and pain in the legs, arms and joints. Kidney damage, as well as anemia, can occur from acute exposure.

CHRONIC

INHALATION/INGESTION: Prolonged exposure to lead and its compounds may produce many of the symptoms of short-term exposure and may also cause central nervous hallucination, convulsions and delirium. Kidney dysfunction and possible injury has also been associated with chronic lead poisoning. Chronic over-exposure to lead has been implicated as a causative agent for the impairment of male and female reproductive capacity, but there is at present, no substantiation of the implication. Pregnant women should be protected from excessive exposure. Lead can cross the placental barrier and unborn children may suffer neurological damage or developmental problems due to excessive lead exposure in pregnant women.

SECTION13---ECOLOGICAL INFORMATION

In most surface water and groundwater, lead forms compounds with anions such as hydroxides, carbonates, sulfates, and phosphates, and precipitates out of the water column. Lead may occur as sorbed ions or surface coating on sediment mineral particles or may be carried in colloidal particles in surface water. Most lead is strongly retained in soil, resulting in little mobility. Lead may be immobilized by ion exchange with hydrous oxides with hydrous oxides or clays or by chelation with humic or fulvic acid in the soil. Lead (dissolved phase) is bioaccumulated by plants and animals, both aquatic and terrestrial.

SECTION14---DISPOSAL INFORMATION

Lead-acid batteries are completely recyclable. Return whole scrap batteries to distributor, manufacturer or lead smelter for recycling. For neutralized spills, place residue in acid-resistant containers with sorbent material, sand or earth and dispose of in accordance with local, state and federal regulations for acid and lead compounds. Contact local and/or state environmental officials regarding disposal information.

© VISION Battery, All Rights Reserved.



© 2009 VISION Group, All Rights Reserved.
Center Power Industrial Park, Tongfu Industrial District Dapeng Town, 518120 Shenzhen, China
Tel: +86-755-8431 8088 Fax: +86-755-8431 8038 E-mail: Sales@vision-batt.com